



# Municipal Corporation ,Jalandhar



From

Assistant Health Officer,  
Municipal Corporation  
Jalandhar.

To

Dayanand Model School,  
Model Town,  
Jalandhar (Pb).

Memo No. 141/HO

Dated. 29/5/2025

Sub: -

Certificate for health & Sanitation for the year 2025-2026.

Reference your letter no.DMS/JAL/14859. Dated .25-04-2025 in the subject cited above.

As per the report of CSI/SI your institution "Dayanand Model School, Model Town, Jalandhar(Pb)" is hereby certified for health & Sanitation as proper hygiene and sanitation is being maintained by the institution. This certificate is being issued on the condition you will comply with the Municipal Solid Waste Management & Handling Rules 2016 regarding collection, segregation and transportation of Solid Waste.

Area Sanitary Inspector will inspect the site periodically, if there is any negligence found, penalty will be imposed. It may further be noted that failure to comply with the above condition permission so granted will be cancelled.

Assistant Health Officer  
Municipal Corporation  
Jalandhar

Principal  
Dayanand Model School  
Model Town, Jalandhar

Manager  
Dayanand Model School  
Model Town, Jalandhar

# MUNICIPAL CORPORATION JALANDHAR

## WATER TESTING LABORATORY

REF. NO:- 324 SAMPLE PROVIDED BY:- *Dayanand Model School*  
*Model Town, Jalandhar*

REF. DT. 29/5/25 SAMPLE COLLECTED:-

SR. NO.	TEST	REQUIRED LIMIT IS10500	SAMPLE (1)	SAMPLE (2)	SAMPLE (3)	SAMPLE (4)
1	COLOUR	5 HAZEN	Colourless			
2	ODOUR	UNOBJECTIONABLE	Odourless			
3	TASTE	AGREEABLE	Notewcl			
4	PH	6.5-8.5	7.2			
5	TOTAL HARDNESS AS CaCO <sub>3</sub>	300 mg/l	140			
6	DISSOLVED SOLIDS(TDS)	500 ppm	240			
7	ALKALINITY	200 mg/l	110			
8	CALCIUM AS Ca <sup>++</sup>	75 mg/l	8.6			
9	IRON	0.3 mg/l	0.1			
10	CHLORIDE	250 mg/l	56.0			
11	SULPHATE	150 mg/l	-			
12	NITRATES	4.5 mg/l	0.1			
13	RESIDUAL CHLORINE	0.2 mg/l	NL			
14	FLUORIDE	1.0 mg/l	0.1			
15	LEAD"	0.05 mg/l	-			
	BACTERIAL TEST					
	TOTAL COLIFORM COUNT		/			
	BY MPN METHOD PER 100ML		NL			
	TOTAL E-COLI COUNT		/			
	BY MPN METHOD PER 100ML		NL			
	TOTAL E-COLI COUNT		/			
	BY COLONY COUNT METHOD					

REMARKS:-

*Provided water sample's tests report is satisfactory*



*Analyst*  
 Municipal Corporation  
 02/06/25