Municipal Corporation ,Jalandhar

From

        Assistant Health Officer,
        Municipal Corporation
        Jalandhar.

To

        Dayanand Model School,
        Model Town,
        Jalandhar (Pb).

Memo No. 141/HD   Dated. 29/5/2025

Sub: -   **Certificate for health & Sanitation for the year 2025-2026.**

Reference your letter no.DMS/JAL/14859. Dated .25-04-2025 in the subject cited above.

As per the report of CSI/SI your institution **"Dayanand Model School, Model Town, Jalandhar(Pb)"** is hereby certified for health & Sanitation as proper hygiene and sanitation is being maintained by the institution. This certificate is being issued on the condition you will comply with the Municipal Solid Waste Management & Handling Rules 2016 regarding collection, segregation and transportation of Solid Waste.

Area Sanitary Inspector will inspect the site periodically, if there is any negligence found, penalty will be imposed. It may further be noted that failure to comply with the above condition permission so granted will be cancelled.

Assistant Health Officer
Municipal Corporation
Jalandhar

MUNICIPAL CORPORATION JALANDHAR

WATER TESTING LABORATORY

(WATER ANALYIS REPORT

REF. NO:- 327 SAMPLE PROVIDED BY:- DayaNand Model School Model Town, Jalandhar

REF. DT. 29/5/25 SAMPLE COLLECTED:-

SR. NO.	TEST	REQUIRED LIMIT IS10500	SAMPLE (1)	SAMPLE (2)	SAMPLE (3)	SAMPLE (4)
1	COLOUR	5 HAZEN	colourless			
2	ODOUR	UNOBJECTIONABLE	odourkess			
3	TASTE	AGREEABLE	Naewcl			
4	PH	6.5-8.5	7.2			
5	TOTAL HARDNESS AS CACO3	300 mg/l	140			
6	DISSOLVED SOLIDS(TDS)	500 ppm	240			
7	ALKALINITY	200 mg/l	110			
8	CALCIUM AS CA++	75 mg/l	8.6			
9	IRON	0.3 mg/l	0.1			
10	CHOLRIDE	250 mg/l	56.0			
11	SULPHATE	150 mg/l	—			
12	NITRATES	4.5 mg/l	0.1			
13	RESIDUAL CHLORINE	0.2 mg/l	Nil			
14	FLUOIDE	1.0 mg/l	0.1			
15	LEAD"	0.05 mg/l	—			
	BACTERIAL TEST					
	TOTAL COLLFORM COUNT					
	BY MPN METHOD PER 100ML		Nil			
	TOTAL E-COLI COUNT					
	BY MPN METHOD PER 100ML		Nil			
	TOTAL E-COLI COUNT					
	BY COLONY COUNT METHOD					

REMARKS:- Provided water sample's tests report is satisfactory

327
02/06/25
Jalandhar

Analyst
Municipal Corporation
02/06/25